



Office
I-4, First Floor, Mukund House,
Azadpur, Delhi-110 033
T: 011 48018197 | M: +91 9871143785

Laboratory
Plot No. 43, HSIIDC, Indl. Estate,
Rai, Sonapat, Haryana-131029
T: 0130 4017631 | M: +91 9215515652

Email/Website
info@metl.co.in
metlson@yahoo.com
www.metl.co.in

TEST REPORT

ULR : TC71832600000758F

Page No. 1/2

Report No: METL/26-27/155/003		Report Date	08/06/2026
Issued To: The Pinnacle School D Block Panchsheel Enclave Near Holiday Club New Delhi 110017		Customer Reference	TPS/Adm/W T/2025-26/1319
		Date of Sample Received	04/06/2026
		Date of test start	05/06/2026
		Date of Completion of test	08/06/2026
Sample Name	Water		
Sample Description	Water		
Sampling Location	-		
Sample Submitted By	Courier	Date of Sampling	04/06/2026
Sampling Method	-	Packing	Steel Bottle
Environmental Condition	34 Deg C	Sample Quantity	1 ltr.
Group Name	Water	Discipline	Chemical

TEST RESULT

S.No.	Test Parameter	Unit	Observed Value	Requirement as per IS:10500-2012 RA 2023		Test Method
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
Chemical Test						
1	Colour	Hazen	<5	5.0 Max	15 Max	IS 3025(Pt-4):2021 Clause No-4.0
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (part 5):2018
3	Turbidity	NTU	0.3	1.0 Max	5 Max	IS 3025(Pt-10):2023
4	pH Value (at 25°C)	--	7.27	6.5 - 8.5	No relaxation	IS 3025(Pt-11):2022
5	Total Hardness (as CaCO3)	mg/l	140	200 max	600 max	IS 3025(Pt-21):2009 RA 2023, Clause No- 5.0
6	Chloride (as Cl)	mg/l	38	250 Max	1000, Max	IS 3025(Pt 32): 2025
7	Total Dissolved Solids	mg/l	260	500 Max	2000, Max	IS 3025(Pt-16):2023
8	Residual Free Chlorine	mg/l	BDL(DL-0.1)	0.2 Min	1.0 Min	IS 3025(Pt-26):2021 Clause No-5.0
9	Iron (as Fe)	mg/l	0.17	1.0 Max	No Relaxation	IS 3025(Pt-53):2024 Clause No-



Scan to check Scope of Accreditation

Chhotu Ram
Technical Manager
Checked by



Mosin Ali
Quality Manager
Authorized Signatory

Terms & Conditions

- The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
- Total liability of our Lab. is limited to the invoiced amount.
- Samples will be destroyed after 30 Days from the date of issue of test report.
- This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



Office
I-4, First Floor, Mukund House,
Azadpur, Delhi-110 033
T: 011 48018197 | M: +91 9871143785

Laboratory
Plot No. 43, HSIIDC, Indl. Estate,
Rai, Sonapat, Haryana-131029
T: 0130 4017631 | M: +91 9215515652

Email/Website
info@metl.co.in
metlson@yahoo.com
www.metl.co.in

TEST REPORT

ULR : TC718326000000758F

Page No. 2/2

Report No: METL/26-27/155/003	Report Date	08/06/2026
--------------------------------------	--------------------	------------

S.No.	Test Parameter	Unit	Observed Value	Requirement as per IS:10500-2012 RA 2023		Test Method
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
9						6.0
10	Fluoride (as F)	mg/l	0.22	1.0 Max	1.5 Max	APHA 24th Edi. 2023(4500 F)

Remarks : The submitted sample conforms to IS:10500-2012 RA 2023 w.r.t. above tests. BDL- Below Detection Limit. DL- Detection Limit.

End of Report



Scan to check Scope of Accreditation



Chhotu Ram
Technical Manager
Checked by



Mosin Ali
Quality Manager
Authorized Signatory

Terms & Conditions

- The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
- Total liability of our Lab. is limited to the invoiced amount.
- Samples will be destroyed after 30 Days from the date of issue of test report.
- This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.

Office
I-4, First Floor, Mukund House,
Azadpur, Delhi-110 033
T: 011 48018197 | M: +91 9871143785

Laboratory
Plot No. 43, HSIIDC, Indl. Estate,
Rai, Sonapat, Haryana-131029
T: 0130 4017631 | M: +91 9215515652

Email/Website
info@metl.co.in
metlson@yahoo.com
www.metl.co.in

TEST REPORT

Page No. 1/1

Report No: METL/26-27/155/003/N		Report Date	08/06/2026
Issued To: The Pinnacle School D Block Panchsheel Enclave Near Holiday Club New Delhi 110017		Customer Reference	TPS/Adm/W T/2025-26/1319
		Date of Sample Received	04/06/2026
		Date of test start	05/06/2026
		Date of Completion of test	08/06/2026
Sample Name	Water		
Sample Description	Water		
Sampling Location	-		
Sample Submitted By	Courier	Date of Sampling	04/06/2026
Sampling Method	-	Packing	Steel Bottle
Environmental Condition	34 Deg C	Sample Quantity	1 ltr.
Group Name	Water	Discipline	Microbiology

TEST RESULT

S.No.	Test Parameter	Unit	Observed Value	Requirement as per IS:10500-2012 RA 2023		Test Method
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
Bacteriological Test						
1	E Coli	-	Absent	Shall not be detectable in any 100 ml sample	----	IS :1622-1981,RA 2019
2	Total Coliform Bacteria	MPN	Absent	Shall not be detectable in any 100 ml sample	----	IS :1622-1981,RA 2019

Remarks : The submitted sample conforms to IS:10500-2012 RA 2023 w.r.t. above tests. BDL- Below Detection Limit. DL- Detection Limit.

End of Report



Chhotu Ram
Technical Manager
Checked by



Mosin Ali
Quality Manager
Authorized Signatory

Terms & Conditions

- The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
- Total liability of our Lab. is limited to the invoiced amount.
- Samples will be destroyed after 30 Days from the date of issue of test report.
- This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.